


- 220/240V —○ 1 Live
- 50Hz —○ 2 Neutral
- Supply —○ 3 Earth
- 4 AI Common
- 5 AI 1
- 6 AI 2
- 7 AI 3
- 8 AI 4
- 9 AI 5
- 10 AI 6
- 11 AI 7
- 12 AI 8
- 13 AO Common
- 14 AO 1
- 15 AO 2
- 16 —○ DO
- 17 —○ 1
- 18 —○
- 19 —○ DO
- 20 —○ 2
- 21 —○
- 22 —○ DO
- 23 —○ 3
- 24 —○
- 25 —○ DO
- 26 —○ 4
- 27 —○
- 28 —○ DO
- 29 —○ 5
- 30 —○
- 31 —○ DO
- 32 —○ 6
- 33 —○
- 34 DI Common
- 35 DI 1 NO/NC
- 36 DI 2 NO/NC
- 37 DI 3 NO/NC
- 38 DI 4 NO/NC

Ribbon Cable
to PSU



25 Pin
Connector

NOTE: All Analog Outputs, Analog Inputs and Digital Inputs should be in screened cable with the screen earthed at the controller end only

| | | | | | |
|---|---------------|--------|---------------|--------------|-------------------------------|
| <p>Ambiflex Tel: 0161 610 7737 Fax: 0161 610 8836 E-mail: sales@ambiflex.com 1 Roebuck Lane, Sale, Cheshire, M33 7SY</p> | Drawing Title | No | Modifications | Date | Drawing No: |
| | | 1..... | | 5/5 | Issue Date: |
| | Project Title | 2..... | | 0/0 | Eng: |
| | 3..... | | 0/0 | First Issue: | Page: of |
| | | | | | 1 1 |